

## Drinking Water Quality and Compliance

(Note: This short form may be used for communities or waterworks serving a population of less than 5000).

### Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Village of Vibank** water quality and sample submission compliance record for the **2021** time period. This report was completed on **January 26, 2022** (must be completed before June 30 each year on a calendar year based reporting frequency). Readers should refer to the Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards

#### Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	24	23	0%
E. coli	0 Organisms/100 mL			

#### Water Disinfection –

##### Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine	0.1 mg/L free OR	0.31-0.61 mg/L	0.26-0.56 mg/L	24	23	100%
Residual	0.5 mg/L total					

#### Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks

##### Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.10	0.21-0.72 mg/L	365	0

A minimum of 0.10 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.10 mg/L free chlorine residual.

#### Turbidity – From Water Treatment Plant Records

Parameter	Limit	Test Level	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Performed	# Tests (NTU)	Range				
Turbidity	<1 NTU	0.10-0.35 NTU	0	0.35 NTU	365	365

#### Chemical – Health Category



Saskatchewan  
Ministry of  
Environment





All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on January 20, 2022. Sample results indicated that the provincial drinking water quality standards were not exceeded. (Use this one if review indicates that there were no exceedences). (OR) Samples exceeded provincial water quality standards for the following parameters: (Use only the applicable portions of table below for which values have been exceeded).

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0013	0	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	1.0		0.0013	0	
Boron		5.0	<0.00696	0	
Bromate	0.01				
Cadmium	0.005		0.00015	0	
Chlorate	1.0				
Chlorite	1.0				
Chromium	0.05		<0.00019	0	
Fluoride (avg*)	1.5		<0.05	0	
Lead	0.01		0.0001	0	
Nitrate (avg.*)	45.0		<0.2	0	
Selenium	0.01		<0.00113	0	
Uranium	0.02		<0.00011	0	

#### General Chemical

Parameter	Aesthetic Objectives * (mg/L)	
Alkalinity	500	109
Bicarbonate	No Objective	133
Calcium	No Objective	2
Carbonate	No Objective	0
Chloride	250	1.3
Conductivity	No Objective	221 uS/cm
Hardness	800	9
Magnesium	200	<1
PH	No Objective	7.4
Sodium	300	44
Sulphate	500	5.2
Total dissolved Solids	1500	188

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required 2020

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.



Saskatchewan  
Ministry of  
Environment



**More information on water quality and sample submission performance may be obtained from:**

Village of Vibank  
Box 204 Vibank SK, S0G 4Y0  
306-762-2130

[village.of.vibank@sasktel.net](mailto:village.of.vibank@sasktel.net)

June 2015    EPB 536D



**Saskatchewan  
Ministry of  
Environment**



**Water Security  
Agency**